

DOWNTOWN DEVELOPMENT AUTHORITY OF THE CITY OF DETROIT
DOWNTOWN PARKING LOT IMPROVEMENT PROJECT – FENCING AND BOLLARD INSTALLATION
NOVEMBER 16, 2023

This Addendum is incorporated into the requirements and contract documents for the Request for Proposals referenced above and shall be so indicated as Addendum No. 3 on the proposal form accompanying the submittal for this project.

All terms and conditions of the Request for Proposal and Addendum No.3 shall remain unchanged except as specifically changed or amended by the following:

Question Responses: The following questions were received from prospective bidders.

- I. **Question:** To confirm - the red circles on the drawings are the actual proposed bollard locations. For example: Site Number 2 shows only 20 bollards, even though the bid form notes "171 lf of bollards..." which would require at least 28 bollards at 6' spacing.

Response: The circles or other marks on the drawings are only meant to show the location of the fencing/bollard, and are **not** meant to show the specific number of bollards/fencing. Bollard spacing should generally align with 6' max spacing, except in circumstances noted in the Scope of Work.

End of Addendum No. 3